

STAT

Sanitized Copy Approved for Release 2010/05/17 : CIA-RDP89-00244R001002480008-4

Page Denied

Sanitized Copy Approved for Release 2010/05/17 : CIA-RDP89-00244R001002480008-4



December 13, 1985

MCI Constructors, Inc.
7649 Dynatech Court
P. O. Box 2786
Springfield, Virginia 22152

Subject: GS-11B-19067, Bid Package No. 3, Powerhouse Modifications,
CIA Headquarters Expansion, Langley, Virginia, File CE 101

Gentlemen:

This is to confirm my instructions to your Mr. Richard Roberts following our meeting on December 5, 1985 with Mr. John J. Kane of Washington Gas.

1. You are to furnish and install pressure regulators (ventless type) on the propane and on the natural gas service each of the four boilers. The regulators are to be suitable for the service and pressures utilized at the boilers, and are to be installed before the three-way valve. A union will also be required in order to facilitate dissassembly.
2. You are to furnish and install a sight-glass with a ball-check for gas flow detection on the purge and vent line for each of the four boilers.

The above requirements were recommended by Washington Gas and your cooperation in implementing same is appreciated.

Your cost for this work is to be included in your proposal for CE #101.

Sincerely,

A handwritten signature in dark ink, appearing to read "Arthur J. Catucci".

Arthur J. Catucci
Project Manager
Headquarters Expansion Project

AJC:nj